



NOTES:

1. USE 3/4" POLYETHYLENE CTS FOR SINGLE SERVICES.
2. USE 1" POLYETHYLENE CTS FOR DOUBLE SERVICES.
3. CONTRACTOR WILL PROVIDE ALL MATERIAL AND INSTALL SERVICES UNDER DCWS SUPERVISION.
4. ALL TAPS WILL BE MADE IN ACCORDANCE WITH DCWS STANDARDS AND AWWA GUIDELINES FOR TAPPING THROUGH POLYETHYLENE ENCASEMENT.

DORCHESTER COUNTY WATER & SEWER	
3/4" - 1" DOMESTIC (NEAR SIDE) WATER SERVICE	DRAWING: W-4 A
DATE: <u>FEB 2022</u>	DRAWN BY: <u>STL</u>
SCALE: <u>NTS</u>	APPROVED BY: <u>JDC</u>