



NOTE:
 AIR RELEASE VALVE SHALL BE
 CRISPIN TYPE "N", MODEL NO. P10
 OR APCO MODEL NO. 200A (1/4"
 ORIFICE, 0 TO 150 PSI WORKING
 PRESSURE, 3/4" NPT CONNECTION
 OR APPROVED EQUAL.

DORCHESTER COUNTY WATER & SEWER	
WATER AIR RELEASE VALVE	DRAWING: W-1
DATE: <u>APRIL 2012</u>	DRAWN BY: <u>JDC</u>
SCALE: <u>NTS</u>	APPROVED BY: <u>KJC</u>